



Türkiye

**Fire test on PN 20 (150 #) and DN 50 (2") BALL Valve**  
**PN 20 (150 #) ve DN 50 (2") Küresel Vana Yangın Testi**

<b>User Kullanıcı</b>	: General / Genel
<b>Project No. Proje No</b>	: 14-B-00616 (001)
<b>Manufacturer İmalatçı</b>	: BURÇELİK VANA Sanayi Ticaret A.Ş. Bursa Sanayi Bölgesi sarı cadde no 15 Nilufer-Bursa - TÜRKİYE
<b>Manufact. project no. İmalatçı Proje no</b>	: Fire Test for PN 20 ( 150 # ) and DN 50 (2") BALL Valve PN 20 ( 150 # ) ve DN 50 ( 2") Küresel vana yangın testi
<b>Manufacturer year İmalat Yılı</b>	: 2015
<b>Drawings No. Resim No.</b>	: In the related Burçelik drawing No: DN50 CLAS 150 Burçelik ilgili Resim No
<b>Max working pres. Max. Çalışma Basıncı</b>	: 20 Bar ( PN 20 (150 #) )
<b>Related test standart Test Standardı</b>	: API 607:2010 & ISO 10497:2010

Valve which has properties PN 20 (150 #) and DN 50 (2") BALL Valve has been Fire tested according to related standarts API 607 and ISO 10497 under observation of TUV SUD Inspector in the BURÇELİK Factory for general using purpose. After the satisfactory results related Fire Test report of valve has been approved by TUV Inspector. TUV SUD Inspector prepared and approved this certificate Due to Client request.

DN 50 (2") ölçüsünde, PN 20 (150 #) basınç sınıfındaki Küre Valf, API 607 ve ISO 10497 standartlarının şartlarına göre Yangın testine tabi tutulmuştur. Yangın testlerine TUV SUD personeli nezaret ederek Test sonucu olumlu bulunan ilgili vanaya ait Yangın testi Raporu onaylanmış ve firma talebi doğrultusunda bu Sertifika düzenlenerek kullanıma sunulmuştur.

<b>First issue date İlk verilmiş tarihi</b>	: 16.06.2015
<b>Test Date Test Tarihi</b>	: 16.06.2015
<b>Validity until Geçerlilik tarihi</b>	: 16.06.2025
<b>Test Place Test Yeri</b>	: Nilufer-Bursa - TÜRKİYE
<b>Qualification Range Temsil aralığı</b>	: DN 50 (2"), DN 65 (2 1/2"), DN 80 (3"), DN 100 (4") PN 20 (150 #), PN 50 (300 #)
<b>Anex Eklər</b>	: Related technical file
<b>Test Result Test Sonucu</b>	: Satisfactory Uygun bulunmuştur.

<b>Place / yer</b>	<b>Date / tarih</b>
Istanbul-TURKEY	16.06.2015

TUV SUD Türkiye  
HAKİM ÖZLÜK